

SECTION 26 05 13.30

MEDIUM VOLTAGE CABLE (5 KV DISTRIBUTION FEEDER)

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Material and installation requirements for:
 - a. Medium voltage cable (601 V and above).
 - b. Cable terminations and splices.
- B. Related Specification Sections include but are not necessarily limited to:
 - 1. **Section 26 08 13** - Medium Voltage Equipment Acceptance Testing.

1.2 QUALITY ASSURANCE

- A. Referenced Standards:
 - 1. Association of Edison Illuminating Companies (AEIC).
 - a. CS8, Specification for Extruded Dielectric Shielded Power Cables Rated 5 Through 46 kV.
 - 2. Institute of Electrical and Electronics Engineers, Inc. (IEEE):
 - a. 48, Standard for Test Procedures and Requirements for Alternating-Current Cable Terminations Used on Shielded Cables Having Laminated Insulation Rated 2.5 kV through 765 kV or Extruded Insulation Rated 2.5 kV through 500 kV.
 - b. 386, Standard for Separable Insulated Connector Systems for Power Distribution Systems Rated 2.5 kV through 35 kV.
 - c. 404, Standard for Extruded and Laminated Dielectric Shielded Cable Joints Rated 2.5 kV to 500 kV.
 - 3. National Electrical Manufacturers Association/Insulated Cable Engineers Association (NEMA/ICEA):
 - a. WC 74/S-93-639, 5 - 46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy.
 - 4. National Fire Protection Association (NFPA):
 - a. 70, National Electrical Code (NEC).
 - b. 70E, Standard for Electrical Safety in the Workplace.
 - 5. National Institute for Certification in Engineering Technologies (NICET).
 - 6. National Institute of Standards and Technology (NIST).
 - 7. Occupational Safety and Health Administration (OSHA).
 - 8. Underwriters Laboratories, Inc. (UL):
 - a. 1072, Standard for Medium-Voltage Power Cables.
 - 9. Build America, Buy America Act (**BABA**).

1.3 SUBMITTALS

- A. Shop Drawings:
 - 1. Product data:
 - a. **Provide submittal data for all products specified in PART 2** of this Specification Section.
- B. Informational Submittals:
 - 1. Product data sheets.
 - 2. Pulling tension, installation instructions.

3. Accessories data sheets (breakout boots, cable glands, special tools, etc).
4. Manufacturer cable test reports.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Ship cable with removable watertight end seals, and store in dry place.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Subject to compliance with the contract documents, the following manufacturers are acceptable:
 1. Wire and cable:
 - a. Prysmian Group.
 - b. Southwire Company.
 - c. United Wire & Cable.
 - d. Approved Equal.
 2. Lugs, connectors and terminations:
 - a. 3M.
 - b. Elastimold by Thomas & Betts.
 - c. Joslyn.
 - d. TE Connectivity Raychem.
 - e. Eaton Cooper Power Systems.

2.2 MEDIUM VOLTAGE CABLES

- A. Ratings:
 1. 5 kV class.
- B. Configuration:
 1. Exposed or concealed power distribution circuit within mining facility.
 2. Three conductor cable and grounding conductor.
- C. Standards:
 1. NEMA/ICEA WC 74/S-93-639: 5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy.
 2. ICEA S-75-381: Portable and Power Feeder Cables for Use in Mines.
 3. AEIC CS8: Specification for Extruded Dielectric Shielded Power Cables Rated 5 through 46 kV.
 4. UL 1072: Type MV-105, For CT USE Direct Buried/Sunlight Resistant.
- D. Conductor Material:
 1. Regular or compressed concentric stranded copper.
- E. Insulation:
 1. Temperature rating: Type MV-105 per NFPA 70.
 2. Ethylene-propylene-rubber (No-Lead EPR).
 3. 133% (115-mil) insulation level.
- F. Shielding:
 1. Shielding on cables rated above 2 kV consists of:
 - a. Free stripping, semiconducting conductor shield.
 - b. Free stripping, semiconducting insulation shield.
 - c. Non-magnetic, 5 mil copper tape over insulation shield with 25% overlap.

2. Color coded polyester ribbon phase identifiers:

VOLTAGE	PHASE A	PHASE B	PHASE C	NEUTRAL	GROUND
12.47 KV	RED	ORANGE	BLACK	N/A	BARE CU
4.16 KV	RED	BLACK	BLUE	N/A	BARE CU
480Y/277 V	BROWN	ORANGE	YELLOW	GREY	GREEN
208Y/120 V	BLACK	RED	BLUE	WHITE	GREEN

G. Grounds:

1. Bare uncoated copper.
2. Size as specified in Bid Documents.

H. Sheath

1. Continuously corrugated & welded armored OR interlocked armored OR polymeric armored cable.

I. Jackets:

1. Waterproof, oil resistant, sunlight resistant outer jacket.
2. Jacket Color Codes:

1000 V OR LESS CABLES	BLACK
5 KV CABLES	YELLOW
15 KV CABLES	RED

2.3 CABLE ACCESSORIES

A. Lugs and Connectors:

1. Lugs:
 - a. Compression type.
 - b. Standard: UL 486A for copper cables
 - c. Voltage rating: Up to 35 kV.
 - d. Current rating: Continuous operation at the rating of the cable.
 - e. Material: Tin-plated copper
 - f. Number of holes: Two, except one on motor leads.
2. Splice connectors:
 - a. Standard: UL 486A for copper cables
 - b. Current rating: Continuous operation at the rating of the cable.
 - c. Material: Tin-plated copper

B. Terminations:

1. End caps:
 - a. Cold or hot shrink.
 - b. Used to environmentally seal and mechanically protect exposed cable ends.
2. Cold shrink kits:

- a. Standard: IEEE 48, Class 1 termination.
 - b. Voltage rating: Same as the cable rating.
 - c. Current rating: Continuous operation at the rating of the cable.
 - d. One-piece design, where high-dielectric constant stress control is integrated within an insulator made of silicone rubber.
 - e. Suitable for contaminated indoor and outdoor locations.
3. Molded rubber kit:
- a. Standard: IEEE 48.
 - b. Voltage rating: Same as the cable rating.
 - c. Current rating: Continuous operation at the rating of the cable.
 - d. One-piece design or modular with stress cone, where high-dielectric constant stress control is integrated within an insulator made of EPDM rubber.
 - e. Suitable for contaminated indoor and outdoor locations.
4. Elbow connectors:
- a. Standard: IEEE 386.
 - b. Voltage rating: Same as the cable rating.
 - c. Current rating: 200A (deadfront, loadbreak) or 600A (deadfront, deadbreak).
 - d. One-piece design, comprised of an insulation shield, insulation layer and an outer shield constructed of EPDM rubber.
 - e. Deadfront, or loadbreak/deadbreak type with:
 - 1) Hot stick pulling eye.
 - 2) Grounding tab.
 - 3) Test point.
 - f. Accessories to be constructed in a similar manner as the elbow connector:
 - 1) Bushing inserts.
 - 2) Bushing well plugs.
 - 3) Feed thru inserts.
 - 4) Protective caps.
- C. Splices:
1. Cold shrink kits:
- a. Standard: IEEE 404.
 - b. Voltage rating: Same as the cable rating.
 - c. Current rating: Continuous operation at the rating of the cable.
 - d. One-piece design, comprised of an insulation shield, insulation layer and a silicone rubber body.
 - e. Suitable for indoor, direct burial or submersible applications.
2. Molded rubber kit:
- a. Standard: IEEE 386 or IEEE 404.
 - b. Voltage rating: Same as the cable rating.
 - c. Current rating: Continuous operation at the rating of the cable.
 - d. One- or multi-piece design, comprised of an insulation shield, insulation layer and an outer shield constructed of EPDM rubber.
 - e. Suitable for indoor, direct burial or submersible applications.
3. Modular separable molded rubber:
- a. Standard: IEEE 386.
 - b. Voltage rating: Same as the cable rating.
 - c. Current rating: 600A.

- d. One-piece design, comprised of an insulation shield, insulation layer and an outer shield constructed of EPDM rubber.
 - e. Deadfront, deadbreak type.
 - f. Components: T-body, insulating plug with cap, insulating plug with cap and stud, and connecting plug.
 - g. Suitable for submersible applications.
4. Motor lead kits:
- a. Voltage rating: Same as the cable rating.
 - b. Current rating: Continuous operation at the rating of the cable.
 - c. Material: EPDM rubber boot with nylon pin.
 - d. On shielded cables provide an additional EPDM rubber cold shrink sleeve.
- D. Cable Shield Grounding Adapters:
- 1. Type: Molded rubber with constant force spring and solder-blocked tinned copper braid pigtail.
 - 2. Waterproof, providing a positive seal for the cable jacket.
 - 3. May be integral with termination of splice device with Engineer's approval.

PART 3 - EXECUTION

3.1 QUALITY CONTROL

- A. Cable manufacturer date must be no more than two years from the ship date.
- B. See Specification Section 26 08 13 for acceptance testing requirements.

END OF SECTION