

South Dakota Science and Technology Authority/
Sanford Underground Research Facility Lead, South Dakota

LZ Davis Campus Infrastructure Improvements

Addendum 4

Issued November 17, 2017

Specification Updates:

Spec Section 23 33 00 - Air Duct Accessories

1. Paragraph 2.2; Revise Paragraph 2.2 to read: "Manual Volume Dampers and Backdraft Dampers"
2. Paragraph 2.2 A. 1. Add subparagraph k. to read: "NCA Manufacturing: Air Balance"
3. Paragraph 2.2 A. Add subparagraph 11. to read: "Backdraft Dampers blade seals to be extruded vinyl or neoprene. Return springs to have adjustable tension for varying differential static pressure. "

Spec Section 23 84 13 - Humidifiers

1. Paragraph 1.2 A. 1. ; Revise Paragraph 1.2 A. 1. to read: "Ultrasonic"
- Paragraph 2.1; Revise Paragraph 2.1 to read: "Ultrasonic Humidifier"

These specifications will be updated in the Project Manual in the coming weeks.