

EXHIBIT D - Ross SPARE Feeder - GE 1200-Amp VCB

		GE Power Vac Breaker		TYPE VB1 13.8-500-3	
				SER. NO. 0357A5704-002-02	
RATED MAX VOLTAGE	15 KV	RATED AMP.	1200	HZ	60
				IMPULSE WITHSTAND	95 KV
					INT TIME 5 CYC
RATED SHORT CIRCUIT AMPS	18 KA	RATED VOLTAGE RANGE FACTOR	1.3	CLOSE & LATCH CAPABILITY AMP.	37 KA
CLOSE COIL	0209B8103G009	VOLTS	125 DC	CLOSING AMPS	6.0
				VOLT RANGE	100-140
TRIP COIL-1	0209B8104G002	VOLTS	125 DC	TRIPPING AMPS	5.9
				VOLT RANGE	70-140
TRIP COIL-2		VOLTS		TRIPPING AMPS	
				VOLT RANGE	
CHARGING MOTOR	0177C5050G004	VOLTS	125VDC	HZ	
CONNECTION DIAGRAM	0209B8250P002	WT	470 LBS	MECH TYPE	ML-18
				DATE MFG.	6/98
VAC. INTER. TYPE	50B1	REQ.:	430-31211	SO:	978465
CAUTION:		BEFORE INSTALLING OR OPERATING READ INST.		GEK-86132	
				GE ELECTRICAL DISTRIBUTION & CONTROL BURLINGTON, IOWA 52601 USA	

GE Power Vac Breaker		TYPE VB1 13.8-500-3	
		SER. NO. 0357A5704-002-02	
RATED MAX VOLTAGE	15 KV	RATED AMP.	1200
		HZ	60
		IMPULSE WITHSTAND	95 KV
			INT TIME 5 CYC
RATED SHORT CIRCUIT AMPS	18 KA	RATED VOLTAGE RANGE FACTOR	1.3
		CLOSE & LATCH CAPABILITY AMP.	37 KA
CLOSE COIL	0209B8103G009	VOLTS	125 DC
		CLOSING AMPS	6.0
		VOLT RANGE	100-140
TRIP COIL	0209B8104G002	VOLTS	125 DC
		TRIPPING AMPS	5.9
		VOLT RANGE	70-140
CHARGING MOTOR	0177C5050G004	VOLTS	125VDC
		HZ	
CONNECTION DIAGRAM	0209B8250P002	WT	470 LBS
		MECH TYPE	ML-18
		DATE MFG.	6/98
VAC. INTER. TYPE	50B1	REQ.:	430-31211
		SO:	978465
INSTRUCTION MANUAL	GEK-86132		

EXHIBIT D - Ross SPARE Feeder - GE 1200-Amp VCB



Stuck Contact - B Phase

