

OIL CLEARANCES FOR TURBINE, REDUCTION GEAR, GENERATOR AND MOTOR BEARINGS

BASIC DIAMETER OF JOURNAL	MINIMUM OIL CLEARANCE WHEN REBABBITTING BEARINGS	MAXIMUM OIL CLEARANCE WHEN REBABBITTING BEARINGS	BEARINGS SHALL BE REBABBITTED AT OR BEFORE THE FOLLOW- ING CLEARANCES ARE REACHED.
Inches	Inches	Inches	Inches
1	0.005	0.007	0.015
2	.005	.007	.015
3	.005	.007	.015
4	.006	.008	.015
5	.007	.009	.015
6	.008	.010	.018
7	.009	.011	.021
8	.010	.012	.024
9	.011	.013	.027
10	.012	.014	.030
11	.012	.015	.033
12	.013	.016	.036
13	.013	.017	.039
14	.014	.018	.042
15	.015	.019	.045
16	.016	.020	.045
17	.017	.021	.045
18	.018	.022	.045
19	.019	.023	.045
20	.020	.024	.045
21	.021	.026	.045
22	.022	.027	.045
23	.023	.028	.046
24	.024	.029	.048
25	.025	.030	.050
26	.026	.031	.052
27	.027	.032	.054
28	.028	.033	.056
29	.029	.034	.058
30	.030	.035	.060