

Inspection & Service Work for Fire Suppression & Fire Extinguishers Q & A

5/17/2018 Written Questions:

1. Will electricity be available for mobile service trailer? – To provide low pressure hydro test and recharge/6-year maintenance can be done during annual maintenance. That would include hydro tester, refill station, dry chemical, valve stems, O-rings, pull pins, bands and other small parts. Service would be done without any delay for removal from property on majority of dry chemical fire extinguishers. **YES**
2. Can we request to separate bid items? Fire Extinguisher and Suppression sales and service to be separate from Sprinkler/Suppression system sales and service bid- I believe the best results will be obtained if vendor specializes in that item. Bid specs would need some adjusting.

Please provide this in your proposal and once we review all bids we will determine what is our best option.

3. Can vendor safety liaison and project manager be the same person? **Contractor will be escorted while on our property with a guide.**