

Asbestos Remediation Projects Q & A

10/18/2017 Written Questions:

1. Is the goal to remove pipe and insulation?
Yes, the goal is to remove pipe and insulation, but some cases may not be practical.
2. Transportation to all areas?
Locomotive as well as walking.
3. Will we be messing with electrical cable?
Yes, but all electrical cable will be de-energized.
4. Size of pipe will be cut into lengths for removal?
3-5 feet sections or whatever the location dictates.
5. Is there any product in the pipes?
Yes, could be
6. Is most insulation tar coating?
Insulation is thin and tar coating, but again this is a case by case, we are currently testing as we come along it.
7. Is the end game replacing or removing the pipe?
We will be removing and replacing all pipe in the pump room and all other areas we will just remove the pipe.
8. Is all pipe horizontal?
Not all pipe is horizontal, some vertical will be encountered.
9. Rough estimate of total quantity hours to do all work?
Two employees for three months minimum per project.