

Questions & Answers
New Pipe Installation at Wastewater Treatment Plant

- Q. When replacing the corroded pipe in the sand filter building, can we isolate that section?
- A. Yes. This scope of the project will be done after the new underground pipe path and the Yardney pump bypass are installed. Those other improvements will allow for this isolation without affecting the rest of the plant.
- Q. Who wires the new PLC components into the existing system?
- A. SDSTA will do any wiring required. Wiring is NOT within the contractor's scope.
- Q. Is Gruvlok an acceptable product in lieu of Victaulic?
- A. Gruvlock is acceptable as long as each fitting meets or exceeds the performance of the specified Victaulic fitting.
- Q. Can the steel pipe be roll grooved in lieu of cut groove ends?
- A. Only cut groove ends are allowed.
- Q. Is there a Wage Determination for this project?
- A. Wage Determination will be added as an exhibit to the General Conditions contract once we award the contract.